CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KRIDL/CSR-09/140c/CEMENT/2016-17 Date: 12.09.2016

TEST REPORT ON CEMENT

* CUSTOMER	:	**Asst. Executive Engineer**, Kodigehalli Sub Division, BBMP, Bangalore.
*AGENCY	:	**Executive Engineer,** KRIDL, Bangalore.
*NAME OF THE WORK	:	Improvements of roads and drains SC colony at Kempapura in Ward No.07, Byatarayanapura, Kodigehalli Sub Division, BBMP, Bangalore.
*REFERENCE	:	BBMP/AEE/BTP/WO/98/2016-17 Dated: 05.08.2016
SAMPLE ID	:	Cement – Sample 2
SAMPLE RECEIVED ON	:	10.09.2016
PERIOD OF TESTING	:	10.09.2016 to 12.09.2016

The results of the tests conducted on the cement sample are as follows:

Sl. No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 8112-2013
1	Standard Consistency	IS-4031 (Part -4) 1988(RA-2009)	29.00 %	-
2	a) Initial Setting Time	IS-4031 (Part -5) 1988(RA-2009)	155 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part -5) 1988(RA-2009)	490 Minutes	Not More than 600 Minutes
3	Soundness by Le Chartlier Method	IS-4031 (Part-3) 1988(RA-2009)	1 mm	Not more than 10mm

*Information is furnished by the Customer/Representative.

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

Assistant Executive Engineer
Kodigehalli Sub Division
Yelahanka Zone, B.B.M.P.
Bangalore.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KRIDL/CSR-09/140c/SAND-Gradation/2016-17 : 12.09.2016

TEST REPORT ON DETERMINATION GRADATION OF FINE AGGREGATES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **Executive Engineer,** KRIDL, Bangalore.

*** Name of Work** : Improvements of roads and drains SC colony at Kempapura in Ward No.07, Byatarayanapura, Kodigehalli Sub Division, BBMP, Bangalore.

Reference : BBMP/AEE/BTP/WO/98/2016-17 Dated: 05.08.2016

Technical Reference : IS : 2386 Part 1 - 1963 RA-2007

Sample ID : Fine Aggregates – Sample 2

Sample Received on : 10.09.2016

Date of Testing : 12.09.2016

Total Wt. of Aggregates in gms **1000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2007)			
		Zone-I	Zone-II	Zone-III	Zone-IV
10	100	100	100	100	100
4.75	95.00	90-100	90-100	90-100	95-100
2.36	75.20	60-95	75-100	85-100	95-100
1.18	54.70	30-70	55-90	75-100	90-100
600 Micron	24.80	15-34	35-59	60-79	80-100
300 Micron	12.80	5-20	8-30	12-40	15-50
150 Micron	5.80	0-10	0-10	0-10	0-15

* Information is furnished by the Customer/Representative

Remarks : This sample is under Zone-I specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

AE(WO)

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KRIDL/CSR-09/140c/AGG/GR/2016-17 : 12.09.2016

TEST REPORT ON DETERMINATION GRADATION OF COARSE AGGREGATES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **Executive Engineer,** KRIDL, Bangalore.

*** Name of Work** : Improvements of roads and drains SC colony at Kempapura in Ward No.07, Byatarayanapura, Kodigehalli Sub Division, BBMP, Bangalore.

Reference : BBMP/AEE/BTP/WO/98/2016-17 Dated: 05.08.2016

Technical Reference : IS : 2386 Part 1 -1963 RA-2007

Sample ID : Coarse Aggregates (40mm)

Sample Received on : 10.09.2016

Date of Testing : 12.09.2016

Total Wt. of Aggregates in gms= **5000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2007)	
		Graded	Single Sized
80	100	100	-
63	100	-	100
40	97.40	95-100	85-100
20	37.40	30-70	0-20
10	13.40	10-35	0-5
4.75	2.40	0-5	-

* Information is furnished by the Customer/Representative

Remarks : This sample is under Graded specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

AE(WO)

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KRIDL/CSR-09/140c/CUBE/2016-17 13.10.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **Executive Engineer,** KRIDL, Bangalore.

*** Name of the work** : Improvements of roads and drains SC colony at Kempapura in Ward No.07, Byatarayanapura, Kodigehalli Sub Division, BBMP, Bangalore.

*** Reference** : BBMP/AEE/BTP/WO/98/2016-17 Dated: 05.08.2016

*** Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{20}

Compressive Strength as on : 28th day

Sample Received on : 13.10.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	15.09.2016	13.10.2016	8.110	479.3	21.30
2	15.09.2016	13.10.2016	8.239	490.3	21.79
3	15.09.2016	13.10.2016	8.380	502.3	22.32

AE-7

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

AE(W7) N.D

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KRIDL/CSR-09/140c/CUBE/2016-17 13.10.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **Executive Engineer,** KRIDL, Bangalore.

*** Name of the work** : Improvements of roads and drains SC colony at Kempapura in Ward No.07, Byatarayanapura, Kodigehalli Sub Division, BBMP, Bangalore.

*** Reference** : BBMP/AEE/BTP/WO/98/2016-17 Dated: 05.08.2016

*** Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{20}

Compressive Strength as on : 28th day

Sample Received on : 13.10.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	15.09.2016	13.10.2016	8.125	485.5	21.58
2	15.09.2016	13.10.2016	8.230	493.2	21.92
3	15.09.2016	13.10.2016	8.310	513.2	22.81

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

AE-I
2

AE(W)

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KRIDL/CSR-09/140c/CUBE/2016-17 13.10.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **Executive Engineer,** KRIDL, Bangalore.

*** Name of the work** : Improvements of roads and drains SC colony at Kempapura in Ward No.07, Byatarayanapura, Kodigehalli Sub Division, BBMP, Bangalore.

*** Reference** : BBMP/AEE/BTP/WO/98/2016-17 Dated: 05.08.2016

*** Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{20}

Compressive Strength as on : 28th day

Sample Received on : 13.10.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	15.09.2016	13.10.2016	8.099	485.5	21.58
2	15.09.2016	13.10.2016	8.198	493.5	21.93
3	15.09.2016	13.10.2016	8.235	510.2	22.68

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

AE(W7)

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KRIDL/CSR-09/140c/CUBE/2016-17 14.10.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **Executive Engineer,** KRIDL, Bangalore.

*** Name of the work** : Improvements of roads and drains SC colony at Kempapura in Ward No.07, Byatarayanapura, Kodigehalli Sub Division, BBMP, Bangalore.

*** Reference** : BBMP/AEE/BTP/WO/98/2016-17 Dated: 05.08.2016

*** Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{20}

Compressive Strength as on : 28th day

Sample Received on : 14.10.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	16.09.2016	14.10.2016	8.235	479.3	21.30
2	16.09.2016	14.10.2016	8.310	499.3	22.19
3	16.09.2016	14.10.2016	8.412	502.3	22.32

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KRIDL/CSR-09/140c/CUBE/2016-17 14.10.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **Executive Engineer,** KRIDL, Bangalore.

*** Name of the work** : Improvements of roads and drains SC colony at Kempapura in Ward No.07, Byatarayanapura, Kodigehalli Sub Division, BBMP, Bangalore.

*** Reference** : BBMP/AEE/BTP/WO/98/2016-17 Dated: 05.08.2016

*** Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{20}

Compressive Strength as on : 28th day

Sample Received on : 14.10.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	16.09.2016	14.10.2016	8.102	485.5	21.58
2	16.09.2016	14.10.2016	8.230	490.3	21.79
3	16.09.2016	14.10.2016	8.310	512.2	22.76

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

AE(W1)

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KRIDL/CSR-09/140c/CUBE/2016-17 17.10.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **Executive Engineer,** KRIDL, Bangalore.

*** Name of the work** : Improvements of roads and drains SC colony at Kempapura in Ward No.07, Byatarayanapura, Kodigehalli Sub Division, BBMP, Bangalore.

*** Reference** : BBMP/AEE/BTP/WO/98/2016-17 Dated: 05.08.2016

*** Sample ID** : Covering slab drain concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{20}

Compressive Strength as on : 28th day

Sample Received on : 17.10.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	19.09.2016	17.10.2016	8.103	475.5	21.13
2	19.09.2016	17.10.2016	8.285	490.3	21.79
3	19.09.2016	17.10.2016	8.317	502.3	22.32

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com